




Airfi Pia hoods

Odour extraction

Test Method EN 13141-3:2017

The test object is measured at height 600 mm



Volume flow		Odour extraction
dm³/s	m³/h	%
20	72	46
30	108	60,1
50	180	76,6
75	270	86,4



Airfi Oy AB
Piilipuunkatu 11
21200 Raisio, Finland

+358 2 430 3300
www.airfi.eu
info@airfi.fi